

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7125-1574:102 Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** ADT Security Services, Inc., 695 Route 46 West, Fairfield, NJ 07004-1561  
Contact: \*Ron Dalton (310) 725-2972 Fax (310) 725-2942

**DESIGN:** Models ADTG1, ADTG1F, ADTG1R and ADTG1RF single gang strobe light, followed by - V15, -V30, -V60, -V75 or -V110. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Electrical: 24-30 VDC  
Candela: 15cd, 30cd, 60cd, 75cd, 110cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical/candela rating and UL label.

**APPROVAL:** Listed as strobe lights for use with separately listed compatible fire alarm control units. For indoor use and wall mount only.

**XLF:** 7125-1591:203 Formerly 7125-1388:232,

\*Rev. 07-01-2003 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JULY 1, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager